



608 N Robinson Ave ~ PO Box 518
Hartington, NE 68739-0518
Phone (402) 254-6758
Fax (402) 254-6759
Website ~ lcnrd.nebraska.gov

August 28, 2019

City of Crofton
Kathy Nohr
PO Box 189
Crofton, NE 68730

Dear Kathy,

Enclosed with your latest billing from CKRWP is a copy of a violation that our water system experienced on April 1, 2019 from the Nebraska Department of Health and Human Services.

Please share this information with all people who drink this water, especially those who may not receive this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting the notices in public places where customers are most likely to see them or distributing copies by hand or mail.

For more information, please contact the Rural Water office at (402) 254-6758.

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Fiedler", written over a horizontal line.

Scott Fiedler
Project Manager

A handwritten signature in black ink, appearing to read "Cope Clark", written over a horizontal line.

Cope Clark
Certified Designated Plant Operator

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirement Not Met for Cedar Knox RWD

Cedar-Knox RWD is required by Nebraska's Regulations Governing Public Water Supplies, Title 179 NAC 3 to collect and submit drinking water samples for regulatory analysis.

Cedar-Knox RWD is required to monitor your drinking water for specific contaminants on a regular basis. Results of monitoring are an indicator of whether or not your drinking water meets health standards. On April 2, 2019 we did not complete follow-up monitoring in the distribution system after monitoring on April 1st indicated the Chlorite level of 1.1 mg/L at the entrance to the distribution system slightly exceeded the MCL of 1.0 mg/L. Therefore we cannot be sure of the quality of your drinking water during that time. Daily monitoring since that time has not indicated any more problems.

The Disinfection byproduct Chlorite is a chemical which may be formed when disinfectants added to the water react with naturally-occurring organic and inorganic matter present in the water

There is nothing you need to do at this time. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

Cedar-Knox RWD regrets its failure to collect follow-up Chlorite samples and will work to ensure that the testing is observed in the future.

For additional information regarding this notice, please contact:

Name: Scott Fiedler

Phone # 402-254-6758

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.